



WEYBURN FIRE DEPARTMENT

Doors, Means of Egress, Fire Curtains, and other Fire Separation Closure Requirements

Doors and Means of Egress	Responsibility
<i>National Fire code of Canada</i> <i>NFPA 80 Standard for Fire Doors and Other Opening Protectives</i>	
Maintained records of tests and inspections on site.	
Exit door hardware shall be in good working condition, and the door shall not be bolted, barred, or locked.	
Doors in fire separations shall not be obstructed, blocked, or wedge open.	
Daily	
Doors in fire separations shall be inspected to ensure they close, latch, and remain closed.	
Monthly	
Doors in means of egress shall be tested to ensure they are operable.	
Yearly	
The safety features of a revolving door shall be tested and inspected by a qualified person.	
Sliding doors that swing vertically for egress shall be tested and inspected by a qualified person.	
Doors with electromagnetic locks shall be tested and inspected by a qualified person.	
Door Holder/Release devices shall be tested and inspected by a qualified person.	
A qualified person shall test and inspect the doors in a fire separation.	
Fire protective curtain assemblies shall be tested and inspected by a qualified person.	
Fire dampers shall be inspected one year after acceptance testing and every four years except In a building containing a hospital, where the frequency shall be every six years.	
Horizontally Sliding, Vertically Sliding, and Rolling Doors shall be tested and inspected by a qualified person.	